

ECI EXPULSION FUSES for DISTRIBUTION TRANSFORMERS

Terminal Board and Bushing Types

MINIMUM CLEARANCES:

Catalog Number	kV	Min. (inches) Clearance to Ground	Min. (inches) Oil Immersion (b)
Terminal Board Type			
9F54DAA---	5.2	2.0	2.5
9F54DAB---	5.2	2.0	2.5
9F54EAA---	5.2	2.0	2.5
9F54EAB---	5.2	2.0	2.5
9F54DBA---	8.4	2.0	2.5
9F54DBB---	8.4	2.0	2.5
9F54EBA---	8.4	2.0	2.5
9F54EBB---	8.4	2.0	2.5
9F54WLD---	15.0	3.0	3.0
9F54DCA---	23.0	6.0 (c)	3.0
9F54DCB---	23.0	6.0 (c)	3.0
9F54ECA---	23.0	6.0 (c)	3.0
9F54ECB---	23.0	6.0 (c)	3.0
9F54DDA---	15.0	5.0	3.0
9F54ddb---	15.0	5.0	3.0
Bushing Type			
9F54VBE---	8.4	5.0	2.5
9F54VBG---	8.4	5.0	2.5
9F54VCE---	15.0	3.0	2.5
9F54VCG---	15.0	3.0	2.5
9F54VDE---	15.0	3.0	2.5

(a) Measured from centerline of fuse tube.

(b) (-5)°C oil to top of fuse tube.

(c) 5.0 inches for 9F54DCA at 15.0 kV.