



United States Department of Agriculture
Rural Development

July 8, 2009

Mr. Wayne A. Wieberg
3-Phase Senior Design Engineer
ERMCO, Three Phase Division
1625 Sylvan Road
Dyersburg, Tennessee 38024

Dear Mr. Wieberg:

Your application for Acceptance of three-phase ECO-Pad has been brought to the attention of Technical Standards Committee "A" (Electric).

The Committee has granted Full Acceptance of your ECO-Pad. The items will appear in the List of Materials as follows:

U he-3.1
July 2009

U he – Padmounted Switchgear
(200 and 600 amp)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>ERMCO</u>	Type ECO-Pad, three-phase, 200 and 600 amp, 15-35 kV

Notes:

1. Enclosures on this page must comply with the deadfront requirements of RUS Spec. U-4.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

1400 Independence Ave, SW • Washington, DC 20250-0700
Web: <http://www.rurdev.usda.gov>


Committed to the future of rural communities.

"USDA is an equal opportunity provider, employer and lender."

To file a complaint of discrimination write USDA, Director, Office of Civil Rights, Room 326-W, Whitten Building, 14th and Independence Avenue, SW, Washington, DC 20250-9410 or call (202) 720-5964 (voice or TDD).

This acceptance does not relieve the manufacturer of any responsibility for the satisfactory performance of the item and its conformity to guarantees, specifications, or other provisions of contracts covering its sale. This acceptance is made with the further understanding that no changes in design or workmanship affecting the quality, strength, or electrical characteristics of the item will be made without the knowledge of the Technical Standards Committees. You are also asked to notify the Technical Standards Committees of any change in manufacturing plant location or locations.

Sincerely,

A handwritten signature in cursive script that reads "Norris W. Nicholson". The signature is written in black ink and is positioned below the word "Sincerely,".

NORRIS W. NICHOLSON
Chair, Technical Standards
Committee "A"
Electric Staff Division
Rural Utilities Service